

Extent of Thermal Hazards Predicted in Four Recent LNG Carrier Spill Studies





Suggested Risk-based Assessment Approach for LNG Carrier Spills






Safety and Consequence Analyses

- Evaluated several breaching events
 - Collisions, groundings, impacts
 - Sabotage and possible attacks
- Evaluated consequences from LNG spills
 - Fire, vapor dispersion, explosions
- Evaluated possibility of cascading damage
 - Cryogenic damage from a spill
 - Thermal damage to structures and LNG vessel from a fire
- Identified high, medium, and low consequence zones for range of possible spills



Analysis of Accidental Breaching of Double Hull Tanker

- LNG tankers designs are robust
- Breaching conditions vary by site
- An LNG container breach can have various results
 - Spill onto water, spill between double hulls, etc.
- Analysis was based on large, 3- D, finite element model results



Analysis of Intentional Breaching of LNG Cargo Tanks

- Assessed "credible threats"
 - Plausible with knowledge and resources
 - Historically observed
- Coordinated analysis with government agencies
- Analysis conducted using modern modeling tools







Summary of Accidental and Intentional LNG Cargo Tank Breach Analyses

- Accidental breach hole sizes of up to 1.5 m²
 (1.3 m diameter) possible
 - No breach for collisions with small boats
 - Conditions for accidental breach unlikely at many sites
 - Current accident safety measures appropriate and effective
- Intentional breach hole sizes of <2 m² up to 12 m² (<1.6 m to 4 m diameter) possible
 - Nominal breach size ~5 m² (2.5 m diameter), smaller than used in many studies
 - Cryogenic damage to ship possible for large spills
- Most events are expected to have an ignition source



Nominal Conditions Used for Spill, Thermal, and Dispersion Analyses

- Spill of 12,500 m³ per cargo tank
- Liquid height of 15 m above the breach
- Used nominal spill conditions
 - Nominal wind and wind speed
 - General discharge and orifice flow parameters
 - Common data for burn rates, surface emissive power, etc.
- Nominal sensitivity analysis of experimental data variation on hazard results
- Cascading damage hazards considered



Thermal Damage and Consequence Considerations

- Two thermal hazard evaluation criteria were considered
 - 35 kW/m² (major structural damage in 10 minutes)
 - 5 kW/m² (2nd degree burns in 30 seconds, NFPA Standard for land-based LNG)
- LNG Foam insulation degradation
 - Some LNG insulation materials (foams) degrade and decompose around 600-800°F
 - Without safety systems operating, top-side foam insulation decomposition on the order of 5 minutes during a fire
- Fires longer than 5 minutes assessed and sequential, cascading cargo tank failures evaluated



Thermal Hazard Analysis Results for Accidental LNG Breaches and Spills

HOLE SIZE (m²)	TANKS BREACHED	DISCHARGE COEFFICIENT	BURN RATE (m/s)	SURFACE EMISSIVE POWER (kW/m²)	POOL DIAMETER (m)	BURN TIME (min)	DISTANCE TO 37.5 kW/m ² (m)	DISTANCE TO 5 kW/m ² (m)
1	1	.6	3X10 ⁻⁴	220	148	40	177	554
2	1	.6	3X10 ⁻⁴	220	209	20	250	784
2	3	.6	3X10 ⁻⁴	220	362	20	398	1358

Uses nominal input parameters from existing data Simultaneous, multiple tank damage highly unlikely



Estimated Impacts to Public Health and Safety from Accidental Spills

	POTENTIAL SHIP	POTENTIAL	POTENTIAL IMPACT ON PUBLIC SAFETY ^a				
EVENT	DAMAGE AND SPILL	HAZARD	~250 m	~250 – 750 m	>750 m		
Collisions: Low speed	Minor ship damage, no breach	Minor ship damage	Low	Very Low	Very Low		
Collisions: High Speed	LNG cargo tank breach from 0.5 to 1.5 m ² spill area	Small fireDamage to shipVapor Cloud	High Med High	Med Low High - Med	Low Very Low Med - Low		
Grounding: <3 m high object	Minor ship damage, no breach	Minor ship damage	Low	Very Low	Very Low		

Very low – little or no property damage or injuries Low – minor property damage and minor injuries Medium – potential for injuries and property damage High – major injuries and significant damage to property



Thermal Hazard Analysis Results for Intentional LNG Breaches and Spills

HOLE SIZE (m²)	TANKS BREACH	DISCHARGE COEFF.	BURN RATE (m/s)	SURFACE EMISSIVE POWER (kW/m²)	TRANS- MISSIV- ITY	POOL DIA. (m)	BURN TIME (min)	DISTANCE TO 37.5 kW/m ² (m)	DISTANCE TO 5 kW/m ² (m)
2	3	.6	3 x 10 ⁻⁴	220	0.8	209	20	250	784
5	3	.6	3 x 10 ⁻⁴	220	0.8	572	8.1	630	2118
5*	1	.6	3 x 10 ⁻⁴	220	0.8	330	8.1	391	1305
5	1	.9	3 x 10 ⁻⁴	220	0.8	405	5.4	478	1579
5	1	.3	3 x 10 ⁻⁴	220	0.8	233	16	263	911
5	1	.6	2 x 10 ⁻⁴	220	0.8	395	8.1	454	1538
5	1	.6	8 x 10 ⁻⁴	220	0.8	202	8.1	253	810
5	1	.6	3 x 10 ⁻⁴	175	0.8	330	8.1	314	1156
5	1	.6	3 x 10 ⁻⁴	350	0.8	330	8.1	529	1652
12	1	.6	3 x 10 ⁻⁴	220	0.8	512	3.4	602	1920

*Nominal case: Expected outcomes of a potential breach and thermal hazards based on credible threats and best available experimental data




Estimated Impacts to Public Health and Safety from Intentional Spills

	POTENTIAL	BATENITIAL	POTENTIAL IMPACT ON PUBLIC SAFETY ^a				
EVENT	SHIP DAMAGE AND SPILL	POTENTIAL HAZARD	~500 m	~500 – 1600 m	>1600 m		
	Intentional, 2-7 m ² breach and medium to large spill	Large fire	High	Med	Low		
		Damage to ship	High	Med	Low		
Insider Threat or Hijacking		Fireball	Med	Low	Very Low		
		Large fire	High	Med	Low		
	Intentional, large release of LNG	Damage to ship	High	Med	Low		
		Vapor cloud fire	High	High - Med	Med ium		
	Intentional, 2-12 m ² breach and medium to large spill	■ Large fire	High	Med	Low		
Attack on Ship		Damage to ship	High	Med	Low		
		■ Fireball	Med	Low	Very Low		

Very low – little or no property damage or injuries Low – minor property damage and minor injuries Medium – potential for injuries and property damage High – major injuries and significant damage to property



Suggested Risk-based Assessment Approach for LNG Carrier Spills





LNG Spill Risk Management Analysis

Risks can be responsibly managed through a combination of approaches:

- Improve risk prevention measures
 - Earlier ship interdiction, boardings, and searches; positive vessel control during transit; port traffic control measures; safety and security zones and surveillance; or operational changes
- Locate LNG terminals where risks to public safety, infrastructures, and energy security are minimized
- Improve LNG safety and security systems
- Improve emergency response, evacuation, and mitigation strategies





- Though limitations in data and modeling exist for LNG spills, current tools, used as identified in the guidance, can help identify and mitigate hazards to the public from a possible spill. As better models and data become available, they can be incorporated into the guidance.
- Consequences from accidental spills using current safety and security practices are generally low.
- Consequences of an intentional breach, absent aggressive prevention strategies, can be more severe than from accidents. The most significant impacts exist within about 500 m of a spill, with much lower impacts at distances beyond 1600 m, even for very large spills.
- Risk-based approaches should be developed in cooperation with stakeholders to reduce risks to public safety and property and compatible with site-specific protection goals.



LNG Spill Analysis and Risk Management Guidance

Zone 1 (High hazard areas)

- Use appropriate and validated analytical models as necessary, especially where interaction with critical infrastructures, terrain, etc. is possible
- Risk prevention and mitigation and emergency response strategies are very important and should be closely coordinated

Zone 2 (Intermediate hazard areas)

 Similar to Zone 1 but less rigorous modeling and risk management operations and strategies required

Zone 3 (Low hazard areas)

 Use of simpler models generally appropriate and nominal risk management operations needed



Report Guidance Designed to Help Sites Evaluate LNG Import Issues

Report provides guidance on assessing site-specific LNG terminal safety and security concerns:

- Site-specific issues
 - location, closeness to critical infrastructures or residential or commercial areas, and available resources
- Assessing potential threats and issues
- Cooperating with stakeholders, public safety, and public officials to identify site "protection goals"
- Modeling and analysis approaches appropriate for a given site, location, or operations
- Assessing system safeguards and protective measures
- Managing risks through cooperative prevention and mitigation to ensure a reliable energy supply while being protective of public safety and property

